## **Informational Water Quality Report**

## Citycheck Standard

Cleveland, OH 44143

ATTN: John Smith

Client:	
Ordered By:	
Smith, John Q. 123 Main Street	



Quality Water Analysis

6571 Wilson Mills Rd Cleveland, Ohio 44143 1-800-458-3330

Sample Number: 20816

Location: Kitchen Sink

Type of Water: City Water

Collection Date and Time: 9/9/2009 00:00

Received Date and Time: 9/10/2009 14:23

Date Completed: 9/14/2009

## **Definition and Legend**

This informational water quality report compares the actual test result to national standards as defined in the EPA's Primary and Secondary Drinking Water Regulations.

Primary Standards: Are expressed as the maximum contaminant level (MCL) which is the highest level of contaminant that

is allowed in drinking water. MCLs are enforceable standards.

Secondary standards: Are non-enforceable guidelines regulating contaminants that may cause cosmetic effects (such as skin

or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water. Individual

states may choose to adopt them as enforceable standards.

Action levels: Are defined in treatment techniques which are required processes intended to reduce the level of a

contaminant in drinking water.

mg/L (ppm): Unless otherwise indicated, results and standards are expressed as an amount in milligrams per liter or

parts per million.

**Minimum Detection** 

Level (MDL):

The lowest level that the laboratory can detect a contaminant.

**ND:** The contaminant was not detected above the minimum detection level.

**NA:** The contaminant was not analyzed.

**√** 

The contaminant was not detected in the sample above the minimum detection level.



The contaminant was detected at or above the minimum detection level, but below the standard.



The contaminant was detected above the standard, which is not an EPA enforceable MCL.



The contaminant was detected above the EPA enforceable MCL.

Status	s Contaminant	Results	Units	National Standa	ards Min.	Detection Level	
	Inorganic Analytes - Metals						
1	Aluminum	ND	mg/L	0.2	EPA Secondary	0.1	
+	Arsenic	0.018	mg/L	0.01	EPA Primary	0.005	
<b>/</b>	Barium	ND	mg/L	2	EPA Primary	0.30	
1	Cadmium	ND	mg/L	0.005	EPA Primary	0.002	
	Calcium	3.1	mg/L			2.0	
1	Chromium	ND	mg/L	0.1	EPA Primary	0.010	
1	Copper	ND	mg/L	1.3	EPA Action Level	0.004	
1	Iron	ND	mg/L	0.3	EPA Secondary	0.020	
	Lead	0.016	mg/L	0.015	EPA Action Level	0.002	
	Magnesium	1.30	mg/L			0.10	
<b>/</b>	Manganese	ND	mg/L	0.05	EPA Secondary	0.004	
1	Mercury	ND	mg/L	0.002	EPA Primary	0.001	
1	Nickel	ND	mg/L			0.020	
<b>√</b>	Selenium	ND	mg/L	0.05	EPA Primary	0.020	
<b>/</b>	Silver	ND	mg/L	0.1	EPA Secondary	0.002	
<b>/</b>	Sodium	ND	mg/L			1	
1	Zinc	ND	mg/L	5	EPA Secondary	0.004	
			Physica	al Factors			
1	Alkalinity (Total)	ND	mg/L			20	
	Hardness	13	mg/L	100	NTL Internal	10	
1	рН	6.8	pH Units	6.5 to 8.5	EPA Secondary		
	Total Dissolved Solids	4.4	mg/L	500	EPA Secondary	1.0	
			Inorganic Ar	nalytes - Other			
1	Bromate	ND	mg/L	0.01	EPA Primary	0.005	
	Chloramine as Cl2	1.4	mg/L			0.1	
<b>√</b>	Chloride	ND	mg/L	250	EPA Secondary	5.0	
	Chlorine-Free	0.60	mg/L			0.05	

Page 2 of 5 9/11/2009 4:10:52 PM Product: Citycheck Standard Sample: 20816

Status	Contaminant	Results	Units	National Sta	andards N	/lin. Detection Level		
	Chlorine-Total	2.0	mg/L			0.1		
<b></b>	Chlorite	ND	mg/L	1	EPA Primary	0.005		
<b></b>	Fluoride	ND	mg/L	4	EPA Primary	0.5		
<b></b>	Nitrate as N	ND	mg/L	10	EPA Primary	0.5		
<b></b>	Nitrite as N	ND	mg/L	1	EPA Primary	0.5		
<b>4</b>	Ortho Phosphate	ND	mg/L	N N		2.0		
1	Sulfate	ND	mg/L	250	EPA Secondary	5.0		
	Organic Analytes - Trihalomethanes							
1	Bromodichloromethane	ND	mg/L			0.002		
1	Bromoform	ND	mg/L			0.004		
<b>/</b>	Chloroform	ND	mg/L			0.002		
<b>/</b>	Dibromochloromethane	ND	mg/L			0.004		
1	Total THMs	ND	mg/L	0.08	EPA Primary	0.002		
		0	rganic Analy	tes - Haloacetic	c Acids			
1	Dibromoacetic Acid	ND	mg/L			0.001		
1	Dichloroacetic Acid	ND	mg/L			0.001		
<b>√</b>	Monobromoacetic Acid	ND	mg/L			0.001		
<b>√</b>	Monochloroacetic Acid	ND	mg/L			0.001		
<b>/</b>	Total HAAs	ND	mg/L	0.06	EPA Primary	0.001		
<b>/</b>	Trichloroacetic Acid	ND	mg/L			0.001		
			Organic A	nalytes - Volati	les			
1	1,1,1,2-Tetrachloroethane	ND	mg/L			0.002		
<b>√</b>	1,1,1-Trichloroethane	ND	mg/L	0.2	EPA Primary	0.001		
<b>/</b>	1,1,2,2-Tetrachloroethane	ND	mg/L			0.002		
<b>√</b>	1,1,2-Trichloroethane	ND	mg/L	0.005	EPA Primary	0.002		
<b></b>	1,1-Dichloroethane	ND	mg/L			0.002		
<b>√</b>	1,1-Dichloroethene	ND	mg/L	0.007	EPA Primary	0.001		
<b></b>	1,1-Dichloropropene	ND	mg/L			0.002		

Page 3 of 5 9/11/2009 4:10:52 PM Product: Citycheck Standard Sample: 20816

Status	Contaminant	Results	Units	National Standa	ırds	Min. Detection Level
1	1,2,3-Trichlorobenzene	ND	mg/L			0.002
1	1,2,3-Trichloropropane	ND	mg/L			0.002
<b>/</b>	1,2,4-Trichlorobenzene	ND	mg/L	0.07	EPA Primary	0.002
1	1,2-Dichlorobenzene	ND	mg/L	0.6	EPA Primary	0.001
1	1,2-Dichloroethane	ND	mg/L	0.005	EPA Primary	0.001
1	1,2-Dichloropropane	ND	mg/L	0.005	EPA Primary	0.002
1	1,3-Dichlorobenzene	ND	mg/L			0.001
1	1,3-Dichlorop <mark>ro</mark> pane	ND	mg/L			0.002
1	1,4-Dichlorobenzene	ND	mg/L	0.075	EPA Primary	0.001
1	2,2-Dichloropropane	ND	mg/L			0.002
1	2-Chlorotoluene	ND	mg/L			0.001
1	4-Chlorotoluene	ND	mg/L			0.001
1	Acetone	ND	mg/L			0.01
<b>-</b>	Benzene	ND	mg/L	0.005	EPA Primary	0.001
<b>-</b>	Bromobenzene	ND	mg/L			0.002
1	Bromomethane	ND	mg/L			0.002
1	Carbon Tetrachloride	ND	mg/L	0.005	EPA Primary	0.001
1	Chlorobenzene	ND	mg/L	0.1	EPA Primary	0.001
1	Chloroethane	ND	mg/L			0.002
1	Chloromethane	ND	mg/L			0.002
1	cis-1,2-Dichloroethene	ND	mg/L	0.07	EPA Primary	0.002
1	cis-1,3-Dichloropropene	ND	mg/L			0.002
1	DBCP	ND	mg/L			0.001
1	Dibromomethane	ND	mg/L			0.002
<b>-</b>	Dichlorodifluoromethane	ND	mg/L			0.002
1	Dichloromethane	ND	mg/L	0.005	EPA Primary	0.002
1	EDB	ND	mg/L			0.001
<b>/</b>	Ethylbenzene	ND	mg/L	0.7	EPA Primary	0.001

Page 4 of 5 9/11/2009 4:10:52 PM Product: Citycheck Standard Sample: 20816

Status	s Contaminant	Results	Units	National Standa	ards	Min. Detection Level
1	Methyl Tert Butyl Ether	ND	mg/L			0.004
1	Methyl-Ethyl Ketone	ND	mg/L			0.01
1	Styrene	ND	mg/L	0.1	EPA Primary	0.001
1	Tetrachloroethene	ND	mg/L	0.005	EPA Primary	0.002
1	Tetrahydrofuran	ND	mg/L	41		0.01
1	Toluene	ND	mg/L	1	EPA Primary	0.001
1	trans-1,2-Dichloroethene	ND	mg/L	0.1	EPA Primary	0.002
1	trans-1,3-Dichloropropene	ND	mg/L			0.002
1	Trichloroethene	ND	mg/L	0.005	EPA Primary	0.001
1	Trichlorofluoromethane	ND	mg/L			0.002
1	Vinyl Chloride	ND	mg/L	0.002	EPA Primary	0.001
1	Xylenes (Total)	ND	mg/L	10	EPA Primary	0.001

We certify that the analyses performed for this report are accurate, and that the laboratory test were conducted by methods approved by the U.S. Environmental Protection Agency or variations of these EPA methods.

These test results are intended to be used for informational purposes only and may not be used for regulatory compliance.

## National Testing Laboratories, Ltd.

NATIONAL TESTING LABORATORIES, LTD

Page 5 of 5 9/11/2009 4:10:52 PM Product: Citycheck Standard Sample: 20816